



we make life better®

2311 Wilson Boulevard Suite 400 Arlington VA 22201 USA
Phone 703 524 8800 | Fax 703 562 1942
www.ahrinet.org

INTERPRETATION
AHRI STANDARDS 550/590 (I-P)-2018 AND 551/591 (SI)-2018
PERFORMANCE RATING OF WATER-CHILLING AND HEAT PUMP WATER-HEATING PACKAGES
USING THE VAPOR COMPRESSION CYCLE

December 19, 2018

References: Section 2.1 Scope

Question: Are 4-pipe chillers covered by AHRI Standards 550/590 and 551/591?

Answer: Air-cooled water-chilling packages with an additional water-cooled heat exchanger (4-pipe chillers) are covered by AHRI Standards 550/590 (I-P) and 551/591 (SI) as air-cooled water-chilling packages and optionally may be certified in the Air-Cooled Water-Chilling Packages Using the Vapor Compression Cycle Certification Program when operating in cooling mode.